

TMC ENGINEERING INC.

ENGINEER: TIEN CHU

Address: 9542 Pacific Avenue, Anaheim, CA 92804
Tel: (714) 829-5053. Email: Tienchu.PE@gmail.com

Backfill and Compaction of Existing Swimming Pool At: 11402 Fredrick Dr, Garden Grove, CA 92840

OWNER: HOANG MA
FROM: TIEN CHU
DATE: 12/21/19

Permit: 19-3556

Dear Mr. Ma

In accordance with your request, on 12/21/19, a Site visit has been performed at the subject site. The purpose of this site visit was to check the compaction of the filled soil at existing pool at the address above.

This letter to certify that the swimming pool at rear of property had filling material generally consisted of medium light brown sand with some silt (have expansion index less than 20) have been compacted to a minimum of 90% every 1 feet lift of maximum density and is consider geotechnical acceptable.

This Report does not guarantee the work of Contractor, nor does it relieve the contractor from performing their work in accordance with the Contract Documents and applicable codes, laws, rules or regulations.

If you have any question please contact us (714-829-5053).

Respectfully,



Tien Chu.



12/21/19